

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 6912-1446:101 Page 1 of 1

**CATEGORY:** Voice Communication Accessories

**LISTEE:** Evax Systems, \*33 Chestnut St., New Haven, CT 06511  
Contact: Peter Binkley (203) 752-1806 Fax (203) 752-1906

**DESIGN:** Model EVX-4Z and EVX-2ZA zone splitters. The unit is intended to be used in conjunction with a listee's separately listed Model EVAX-25 audio adjunct system (CSFM Listing No. 6911-1446:100). Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** Input: 24-28 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, wiring diagram, applicable codes and ordinances and in a manner which is acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as a voice communication/audio adjunct system accessories.

\*Rev. 08-04-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 18, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**